



Residential Water Chemistry Information

(Post Water Treatment Plant)

2018 Levels

Alkalinity* (Total Alkalinity as CaCO ₃)	255 mg/L
*Alkalinity may be stated as CaCO ₃ , CO ₃ , or "carbonate" content	
Calcium	87.5 mg/L
Chloride	80.1 mg/L
** SMCL 250 mg/L	
Iron	.015 mg/L
** SMCL 0.3 mg/L	
Manganese	0.002 mg/L
** SMCL 0.05 mg/L	
Magnesium	39.6 mg/L
pH	7.1
Sodium	26.4 mg/L
Sulfate	83.8 mg/L
Total Hardness	22.2 gpg (Grains per Gallon)

**** SMCL (Secondary Maximum Contaminant Level):** Per the EPA, this is a set of 15 non-mandatory water quality standards that has been established to assist public water systems manage the aesthetics of their drinking water supply (such as color, taste, or odor.) These contaminants are not considered to present a risk to human health at the SMCL.